NEW WATER CHILLER SCHEDULE (TO BE INSTALLED)

| TAG NO. | SYSTEM | MAKE | MODEL | NOMINAL CAPACITY (TONS) | COMPRESSOR DATA | | | | | | COMPRESSOR DATA | | | | | | ELECTRICAL DATA | | | | | |
					TYPE	TYPE	QTY	SIZE TONS/COMP.	NO. INDEPENT CIRCUITS	REFRIG TYPE	TONS AT RATING	GPM	O.S.A. DB °F	ENT. WTR °F	LVG. WTR °F	CAP. STEPS	RATED VOLTS	PHASE	FLA AMPS	LRA AMPS	CONTROLS	ACCESSORIES AND OPTION BY MANUFACT
CH-1	MAIN CENTRAL CHILLER	CARRIER	30RAP050	50	AIR COOLED LIQUID CHILLER	HERMETIC SCROLL	4	12.5	2	R-410A	46.1	120	100	55	45	4	208V	3	236.0	453.9	MICROPROCESSOR	SEE BELOW

NEW CHILLER OPTIONS AND ACCESSORIES SUPPLIED BY MANUFACTURER

1. CONDENDER COILS CONSTRUCTED OF FACTORY E-COATED "MICRO CHANNEL". FULL EXTENDED WARRANTY.
2. CONTROL POWER TRANSFORMER.
3. WATER FLOW SWITCH.
4. COIL PROTECTION GRILLES.
5. GFCI RECEPTABLE.
6. FACTORY INSTALLED NON-FUSED DISCONNECT.
7. DIGITAL COMPRESSOR CONTROL

8. SET ONBOARD CONTROL TO SUPPLY 45°F CHILLED WATER.
9. SET REMOTE CHILLER ENABLE CONTACT VIA CHILLER CONTROL PANEL. LOCATED IN THE PUMP ROOM.

EXISTING WATER CHILLER SCHEDULE (TO REMAIN OPERATIONAL)

| TAG NO. | SYSTEM | MAKE | MODEL | NOMINAL CAPACITY (TONS) | COMPRESSOR DATA | | | | | | COMPRESSOR DATA | | | | | | ELECTRICAL DATA | | | | | |
					TYPE	TYPE	QTY	SIZE TONS/CIRC.	NO. INDEPENT CIRCUITS	REFRIG TYPE	TONS AT RATING	GPM	O.S.A. DB °F	ENT. WTR °F	LVG. WTR °F	CAP. STEPS	RATED VOLTS	PHASE	FLA AMPS	LRA AMPS	CONTROLS	ACCESSORIES AND OPTION BY MANUFACT
CH-2	MAIN CENTRAL CHILLER	CARRIER	30RA050	50	AIR COOLED LIQUID CHILLER	HERMETIC SCROLL	4	12.5	2	R-22	50.7	120	85	55	45	4	208V	3	184	XXX	MICROPROCESSOR BASED	

(EXIST. CARRIER CHILLER TO REMAIN OPERATIONAL)

EXISTING WATER CHILLER SCHEDULE (TO BE DEMOLISHED)

| TAG NO. | SYSTEM | MAKE | MODEL | NOMINAL CAPACITY (TONS) | COMPRESSOR DATA | | | | | | COMPRESSOR DATA | | | | | | ELECTRICAL DATA | | | | | |
					TYPE	TYPE	QTY	SIZE TONS/CIRC.	NO. INDEPENT CIRCUITS	REFRIG TYPE	TONS AT RATING	GPM	O.S.A. DB °F	ENT. WTR °F	LVG. WTR °F	CAP. STEPS	RATED VOLTS	PHASE	FLA AMPS	LRA AMPS	CONTROLS	ACCESSORIES AND OPTION BY MANUFACT
CH-1	MAIN CENTRAL CHILLER	TRANE	CGAD-C50	50	AIR COOLED LIQUID CHILLER	N/A	X	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

(EXIST. TRANE CHILLER TO BE REMOVED)

5. PROVIDE SUBMITTAL TO RESIDENT ENGINEER (COTR) FOR REVIEW AND APPROVAL.